



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
TWAD Board, Siruvani Nagar Campus., 30, Bharathi Park Road,
Coimbatore - 641043.

Phone: 0422 - 2437863

E-mail: twadlabce@gmail.com

TEST REPORT

Sample Receipt No/Date :	49566- 49567/Dt.25.06.2024
Invoice Details :	8743/Dt.25.06.2024/Amt.1652/-
Customer Name and Address :	The Principal, Nehru International School, "Jawahar Gardens", Kaliapuram, Coimbatore.
Test Commenced on :	25.06.2024
Test Completed on :	26.06.2024
Test Report Date :	27.06.2024
SAMPLE DETAILS FURNISHED BY CUSTOMER	
Source :	BoreWell/PP (RO)
Location :	Within the School Premises
Sample drawn by/Date	Customer/25.06.2024
Quantity Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
The test result of sample received is as follows.	

S.No	I. CHEMICAL EXAMINATION	Method of Testing	Unit	Sample No. 49566 Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit
1	pH at 25°C	IS 3025 Part 11-1983	-	6.8	6.5-8.5	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025-Part 23-1986	mg/L	8	200	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009	mg/L	24	200	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	20	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24-1986	mg/L	< 5.0	200	400
6	Nitrate as NO ₃	APHA 23rd Edition 2017- 4500 -NO ₂ B	mg/L	12	45	45
7	Fluoride as F	APHA 23rd Edition 2017 - 4500- F-D	mg/L	< 0.2	1.0	1.5

Contd..

Note:

1. The test results relate only to the tested sample.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.



**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY**

**TWAD Board, Siruvani Nagar Campus., 30, Bharathi Park Road,
Coimbatore -641043.**

Phone: 0422 - 2437863

E-mail: twadlabce@gmail.com


TEST REPORT

Sample Receipt No/Date :	49566- 49567/Dt.25.06.2024
Invoice Details :	8743/Dt.25.06.2024/Amt.1652/-
Customer Name and Address :	The Principal, Nehru International School, "Jawahar Gardens", Kaliapuram, Coimbatore.
Test Commenced on :	25.06.2024
Test Completed on :	26.06.2024
Test Report Date :	27.06.2024
SAMPLE DETAILS FURNISHED BY CUSTOMER	
Source :	BoreWell/PP (RO)
Location :	Within the School Premises
Sample drawn by/Date :	Customer/25.06.2024
Quantity-Received :	2 litres
Sample Container :	Plastic
Condition of the Sample :	Good Condition
Appearance, Colour, Odour :	Clear/Colourless/Agreeable
The test result of sample received is as follows.	

S.No	I. Physical Examination	Method of Testing	Unit	Sample No. 49566 Result	Specification as per IS 10500 : 2012	
					Acceptable limit	Permissible Limit
1	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
2	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	69	500	2000
3	Electrical Conductivity	APHA 23rd Edition 2017 - 2510 B	µS/cm	101	-	-
	II. Chemical Examination					
4	Ph. Alkalinity as CaCO ₃	IS 3025-Part 23-1983	mg/L	0	-	-
5	Calcium as Ca	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	5	75	200
6	Magnesium as Mg	APHA 23rd Edition 2017- 3500 Mg B	mg/L	3	30	100
7	Sodium as Na	APHA 23rd Edition 2017 - 3500 Na B	mg/L	10	-	-
8	Potassium as K	APHA 23rd Edition 2017 - 3500 K B	mg/L	1	-	-
9	Iron as Fe	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0	0.3	1.0
10	Manganese as Mn	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0	0.1	0.3
11	Free Ammonia as NH ₃	APHA 17th Edition-1989- 4500 NH3C	mg/L	0.2	0.5	0.5
12	Nitrite as NO ₂	APHA 23rd Edition 2017- 4500-NO3 B	mg/L	0	-	-
13	Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.37	-	-
14	Tidy's Test 4 hrs as O ₂	APHA 23rd Edition 2017 - 4500 O - B	mg/L	0.16	-	-
	III. Bacteriological Examination			49567		
15	Feacal Coliform per 100 ml	IS/APHA	CFU	0	0	0

Remarks: The tested sample is confirmed to IS: 10500:2012 drinking water specification with respect to above tested parameters.

.....End of the report.....


 25/6/2024
 Assistant Water Analyst,
 TWAD Bd, D.W.T. Lab,
 Coimbatore.
 Coimbatore

Note:

1. The test results relate only to the tested sample.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.